



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5146BT0236

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Distributor <i>Vertreiber</i>	EURO-LOCK GmbH Nordweststraße 3, D-59387 Ascheberg
Product Category <i>Produktart</i>	greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)
Product Description <i>Produktbezeichnung</i>	sealing material for metallic screwed joints in gas appliances, gas equipments and water heating equipments, not allowed in the gas installation according to DVGW-TRGI 2008
Model <i>Modell</i>	A62.00
Test Reports <i>Prüfberichte</i>	laboratory control test: 18/011/5146/03 from 21.03.2018 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 751-1 (01.05.1997)

Date of Expiry / File No. 06.06.2023 / 18-0316-GNV
Ablaufdatum / Aktenzeichen

19.04.2018 Fi C-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type	Technical Data	Remarks
Typ	Technische Daten	Bemerkungen
A62.00	class: H	for diameters > DN 10 up to DN 50

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

suitable for: metal thread connections for application by coarse threads
not permissible: for application in gas-installations according to DVGW-TRGI 2008

DVGW